

Franken Maxit Mauermörtel GmbH & Co. · Industriestr. 1 · D-94559 Niederwinkling

Product Management
SIGA
Rütmattstraße 7
6017 Ruswil
Schweiz

**Franken Maxit Mauermörtel
GmbH & Co.**

Industriestraße 1
D-94559 Niederwinkling
Telefon (0 99 62) 94 14 - 0
Telefax (0 99 62) 94 14 - 410
Internet: www.franken-maxit.de
www.solarfarbe.de

Abt./Bearb. BR/Ke Tel.0173-5760306 19.07.2012

Dear Sir / Madam,

We have tested the plastering ability of SIGA Fentrim 20 and SIGA Fentrim 2.
Adhesion tests were carried out for both the adhesive tapes using the following products:

SIGA Fentrim 20 (for indoor application)

maxit ip 23 F Lime-gypsum-machine plaster,
plaster group P IV according to DIN V 18550, B3 according to DIN EN 13279-1.

maxit ip 22 E Gypsum-machine-lightweight plaster,
plaster group P IV according to DIN V 18550, B4 according to DIN EN 13279-1.

maxit pluscalc 381 Pluscalc-interior plastering,
ecological interior plastering, CS I according to DIN EN 998-1

SIGA Fentrim -2 (for outdoor application)

maxit multi 261 renovation plaster, grey,
plaster group P II according to DIN V 18550, CS III according to DIN EN 998-1.

maxit multi 262 renovation plaster, light coloured,
plaster group P II according to DIN V 18550, CS III according to DIN EN 998-1.

maxit multi 285 adhesive and reinforcing plaster,
plaster group P II according to DIN V 18550, CS III according to DIN EN 998-1.

maxit multi 290 E adhesive and reinforcing plaster, plaster group P II according to DIN V 18550, CS III according to DIN EN 998-1.

The tested products have an excellent bonding with the two joint sealing tapes, SIGA Fentrim 20 and SIGA Fentrim 2.

Yours sincerely
Structural consultant Franken Maxit
Josef Kerscher
Tel. 0173-5760306
Fax: 09962-9414-469
email: Josef.Kerscher@franken-maxit.de



on behalf of Josef Kerscher